

SECTION 6

6.19 OUTSIDE METER SETTINGS:

All outside meters shall be installed in a horizontal position and housed in a concrete manhole or vault, and shall conform to Sheets 47, 51, 56, 57, 58, 59, 70, 71, 72, 73 and 74 of the Standard Drawings.

Each Water meter dial shall be equipped with an Itron Model 40W-1 pit ERT with remote antenna unit, mounted in accordance with Denver Water's standards.